



Alberta Boilers Safety Association

STATUTORY DECLARATION
Registration of Fittings

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.

I, James W Kolbus,

Product Manager

(company title, e.g. vice president, plant manager, chief engineer) (must be in a position of authority)

of Clark-Reliance Corporation
(name of manufacturer)

located at 16633 Foltz Industrial Parkway Strongsville, OH USA
(plant address) 44149

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

comply with the requirements of _____ which specifies the dimensions, materials of (title of recognized North American Standard)

construction, pressure/temperature ratings and identification marking of the fittings, or

are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with ASME Boiler Code as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

(A) Section 1

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, Hartford Steam Boilers as being suitable for the manufacture of these fittings to the stated standard.

The fittings covered by this declaration, for which I seek registration, are Level Measuring Devices

In support of this application, the following information, calculations and/or test data are attached: Bronze and Steel Water Gage Values, Cond S Type Prismatic Gages, Flat Glass Water Gages, Simplipart Bicolor Water Gage Glasses, Electro Eye-Hyge Remote Level Indication Systems

DECLARED before me at Clark-Reliance in the City of Strongsville in the Cuyahoga County of State of Ohio

this 14th day of November AD 2003

(print) JOAN M. FAUS

James W Kolbus
(Signature of Applicant)

(sign) Joan M. Faus
(Commissioner of Oaths)

Joan M. Faus
Notary Public, State of Ohio
My Commission Expires May 30, 2005

For Office Use Only

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category C

Registration Number: 006569.2 See notes in the acceptance letter [Signature] DJORDJE SRNIC
(For the Administrator/Chief Inspector of Alberta)

Date Registered: SEP 15 2004

Expiry Date: 2014-09-15



Alberta Boilers Safety Association

#200, 4208 - 97 Street

Edmonton, Alberta, Canada T6E 5Z9

Tel: (780) 437-9100 / Fax: (780) 437-7787

September 15, 2004

James W. Kolbus
CLARK-RELIANCE CORPORATION
16633 FOLTZ INDUSTRIAL PARKWAY
STRONGVILLE, OH USA, 44149

Dear James W. Kolbus,

The drawings, specifications and/or information received on September 15, 2004 are accepted for registration as follows:

CRN :	0C6569.2	Accepted on:	September 15, 2004
Tracking No. :	2004-06823	Expiry Date:	September 15, 2014
Reg Type :	New Design		
Drawing No. :	CATALOG 500, SECTIONS AB5.2C AND AB5.4C Rev - As Noted		
Fitting Desc:	STEEL WATER GAGE VALVES		

Registered under owner / manufacturer name CLARK-RELIANCE CORPORATION

The registration is conditional on your compliance with the following notes:

The scope of this registration includes the following fittings:

- Steel water gauge valves, series 600, 700 and 800.
- Model SG858 is not part of this registration.
- For models SG885 and SG885U, the maximum pressure is 1135 PSI at 560 deg. F.
- For other models in series 800, maximum pressure is 1500 PSI at 596 deg. F.
- Valve body material specification is SA-105.
- Minimum valve body thickness is 0.2475 in.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

Enclosed are stamped prints for your reference.

Sincerely,

SRNIC, DJORDJE, P. Eng.
Design Survey Engineer