

16433 Foltz Pkwy Strongsville, Ohio 44149 Telephone: (440) 572-1500 Fax: (440) 572-0900
www.clark-reliance.com



Natural Gas Elements

Filtration Efficiency Rating: ISO 16889

<u>Element Part Number</u>	<u>Solid particle removal</u>
2700GA	0.3 @ 99%
2710E1	0.3 @ 99%
2710E2	0.3 @ 99%
2710E3	0.3 @ 99%
2710H2	0.3 @ 99%

Performance Data

Recommended Changeout: 15 PSID or 18 months
Temperature, max: 400 °F continuous, 450 °F intermittent

Material of Construction

Media: Multiple layers of synthetic materials with stainless steel wire mesh
Hardware: Stainless steel
Pleat support: Heavy gauge stainless steel perforated sheet
Gasket: Silicone or Viton

Packaging

Quantity per carton: 1
Weight: Varies